



NOTES:

1. CONCRETE: 4000 PSI AFTER 28 DAYS
2. REINFORCING: 6X6/10X10 W.W.M. & FIBERS
3. KEYED JOINT SEALED WITH BUTYL RUBBER
4. EXCAVATION MUST BE AT LEAST 12" LONGER AND WIDER THAN TANK SIZE.

RICHARD GENEST, INC.

**2000 GALLON
GREASE TRAP**