



NOTES:

1. CONCRETE: 4000 PSI AFTER 28 DAYS
2. REINFORCING: 6X6/10X10 W.W.M. & FIBERS
3. KEYED JOINT SEALED WITH BUTYL RUBBER
4. EXCAVATION MUST BE AT LEAST 12" LONGER AND WIDER THAN TANK SIZE.
5. HD TANKS HAVE A 6" TOP & #5 12 O.C. EACH WAY

LIQUID CAPACITY (GALLONS)	TOTAL HEIGHT A	INLET INVERT HEIGHT B	WEIGHT (LBS)
1000	49"	38"	9500
1250	56"	45"	10500
1500	64"	53"	11000
2000	76"	64"	12500

RICHARD GENEST, INC.
TWO COMPARTMENT
LEDGE SEPTIC TANK