



COMPONENT	WEIGHT (LBS)	APPLICATION CHART
BASE	15900	750 - 2000 KVA
COVER	10900	750 - 2000KVA

**NOTES:**

1. CONCRETE: 5000 PSI AFTER 28 DAYS
2. REINFORCING PER CMP SPECIFICATIONS
3. EXCAVATION MUST BE AT LEAST 12" WIDER AND LONGER THAN PAD SIZE



**CMP 3 PHASE 9 X 9 TRANSFORMER PAD**

**238 Country Club Road (Route 4) Sanford, ME 04073**

**(207) 324-7215 (800) 477-8177**

**Date: 8/17/2009**