

- 4. SEE SHEET "REQUIREMENTS FOR PADMOUNTED TRANSFORMER SLAB DETAILS"
- 5. I INCH PVC CONDUIT FOR GROUND GRID LEADS.
- 6. SEE SHEET "PAD-MOUNT EQUIPMENT GROUNDING GRID" DTR 56.223
- 7. EXCAVATION MUST BE AT LEAST 12" WIDER AND LONGER THAN PAD



PSNH SINGLE PHASE TRANSFORMER PAD

238 Country Club Road (Route 4) Sanford, ME 04073

(207) 324-7215 (800) 477-8177

Date: 8/20/2025