






COMPONENT	WEIGHT (LBS)	APPLICATION CHART
BASE	8200	75 - 500 KVA
COVER	6050	75 - 500 KVA

NOTES:

1. CONCRETE: 5000 PSI AFTER 28 DAYS
2. REINFORCING PER CMP SPECIFICATIONS
3. EXCAVATION MUST BE AT LEAST 12" WIDER AND LONGER THAN PAD SIZE



CMP 3 PHASE 7 X 7 TRANSFORMER PAD

238 Country Club Road (Route 4) Sanford, ME 04073

(207) 324-7215 (800) 477-8177

Date: 8/18/2025